AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Fyber Flooring

Sample Description

Suite 302

Level 3 35 Buckingham Street

Surry Hills NSW 2010

Clients Ref: "Express Weave"

Cut pile Axminster carpet on Durafit 7 Underlay

Colour : Multicolour End Use : Flooring

Nominal Composition: 80% Wool 20% Nylon

AS/ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

Test Number :

Issue Date

Print Date

19-003810

3/09/2019

15/08/2023

Yes

Radiant Heat Source

Date of Sample Arrival 08/07/2019
Date Tested 26/08/2019

CHF Value	1	2	3	Mean	
Length	9.2	-	-	-	kW/m²
Width	5.4	6.7	6.5	6.2	kW/m²
Smoke Value	1	2	3	Mean	
Length	52	-	-	-	%.min
Width	126	70	109	102	%.min

Melting Yes

Penetration of flame through to substrate

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

HF30 not reported as flame out time occurred before 30 minutes.

301834 37406 Page 1 of 2

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



MICHAEL A. JACKSON B.Sc.(Hons)

Fiona McDonald

APPROVED SIGNATORY



Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Fyber Flooring

Suite 302

Level 3 35 Buckingham Street

Surry Hills NSW 2010

Test Number : 19-003810

Issue Date : 3/09/2019
Print Date : 15/08/2023

Each specimen was adhered to Durafit 7 underlay using R95 adhesive and then bonded to 6mm thick fibre reinforced cement board using R656 adhesive and clamped prior to testing

301834 37406 Page 2 of 2

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



IICHAEL A. JACKSON B.Sc.(Hons)

Fiona McDonald

APPROVED SIGNATORY